



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code 46.2-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R317 Protection of wood and wood based products against decay		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Change section R317.1, item #3 as follows: ...impervious moisture barrier, <u>or unless such slab is separated from the ground by a vapor retarder.</u></p> <p>Add an exception to R317.1, item #7 as follows: <u>Exception: Exterior basement walls, below grade, complying with section R406.</u></p> <p>Bring forward the amendment to R319.1.2 in the 2005 InRC and change the title as follows: <u>R319.1.2 Geographical areas. R317.1.3 Exposed exterior above grade structural framing.</u></p> <p>Change R317.2 as follows: ...of the product that has been approved <u>accepted</u> by an accreditation body...</p>		
REASON AND FISCAL IMPACT		
<p>This proposal brings forward amendments to this section from the 2005 InRC. Some of the previous amendments are no longer needed since the requirements of the Indiana amendments are now in the IRC text.</p> <p>Fiscal impact: there is no increase to the cost of construction.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		